

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE

LISTING No. 7165-1559:100

Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Allestec Corp., 810 Russell Palmer Rd., Kingwood, TX 77339
Contact: Leslie Larson (281) 359-1519 Fax (281) 359-2085*

DESIGN: Model 800 special hazard fire alarm control unit. Refer to listee's data sheet for additional detailed product description and operational considerations.
System Components:

| | |
|--------------------|--------------------|
| 800-1436, 800-1437 | Abort Modules |
| 800-1440 | Input Module |
| 800-1441 | Manual Pull Module |
| 800-1442 | Alarm Module |
| 800-1443 | Release Module |
| 800-1444 | Fault Module |

RATING: 120 VAC, 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and FM label.

APPROVAL: Listed as fire alarm control unit for special hazard industrial applications where two reliable and independent means of 24 VDC power are provided. Not approved for use in CSFM regulated occupancies. Authority having jurisdiction shall be consulted prior to installation.

NOTE: This control unit is designed for use in industrial special hazard applications like compressor/pipeline pumping stations, marine loading terminals, utility power stations, etc. This unit meets NFPA 72 and FMRC 3820 standards. However, it has not been tested to UL 864.

*Rev. 06-06-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager